

GLAS-DOR INSTALLATION SELF-INSPECTION CHECKSHEET

GLAS-DOR complies with industry standards for fire safety performance **when fitted in accordance with EN1634-1 (doorsets) or EN 1364-1 (screens), and registered as being installed as per our installation instructions.**

This self-inspection checksheet forms part of the fire certification of the doorset, and therefore **MUST** be completed and returned to Robust UK following installation.

Failure to complete and return this form will invalidate the fire certification.

Order No	
Customer	
Installation Co	
Installer Name	

Email	
Tel No	
Date	
Signed	

Requirement - Doors	✓	Initial
Supplied glass fitted		
Promatec H setting blocks used		
Certification labelling from factory remains in place		
Frame-wall gap 10mm-30mm		
Door closer set up		
Door latches		
Door-frame gap 10mm		

Requirement - Screens	✓	Initial
Supplied glass fitted		
Promatec H setting blocks used		
Certification labelling from factory remains in place		
Frame-wall gap (bottom) 5-15mm		
Frame-wall gap (sides & top) 15-30mm		

Upon completion, this form must be returned to customer.service@robust-uk.com